

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1180666

Product: Switchgear for electrometers

Type: EJ1R, 2EJ1R
E1R, 2E1R, 3E1R, 4E1R
E2R, 2E2R, 3E2R, 4E2R

Rating: 3x 230/400 V, 50 Hz, to 63 A, IP 44/20C

Ordering firm: SFOS.SK s.r.o.
Školská 1901, 979 01 Rimavská Sobota, Slovakia

Manufacturer: SFOS.SK s.r.o.
Školská 1901, 979 01 Rimavská Sobota, Slovakia

Trade mark:

The test results are stated in the test-report No.: 802756-01/01 of: 24.09.2018

A sample of the product was found to be in conformity with:

ČSN EN 61439-1 ed. 2:12, ČSN EN 61439-3:12

cl. 6, 10.2.6, 10.2.7, 10.3, 10.4, 10.9.2, 10.9.4, 10.10.4, 10.11.2, 10.12 (J.9.4.3.1, J.9.4.4.1), 10.13

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 802756 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 117/2016 Sb. (2014/30/EU), 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.10.2021

08.10.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 1 1 8 0 6 6 6 *

802756-01